



FLORIDA DEPARTMENT OF

# Business & Professional Regulation



DBPR HOME ABOUT DBPR DBPR DIVISIONS CONTACT DBPR



License efficiently. Regulate fairly.

OFFICE OF THE SECRETARY

|                          |   |
|--------------------------|---|
| FL #                     | FL4483-R5   |
| Application Type         | Editorial Change  |
| Code Version             | 2010  |
| Application Status       | Approved  |
| Comments                 |   |
| Archived                 | <input type="checkbox"/>  |
| Product Manufacturer     | Petersen Aluminum Corporation   |
| Address/Phone/Email      | 102 Northpoint Parkway<br>Building 106<br>Acworth, GA 30102<br>(800) 272-4482<br>dlandis@petersenmail.com |
| Authorized Signature     | Sal Delfino<br>saldelfino@att.net   |
| Technical Representative | Dave Landis   |
| Address/Phone/Email      | 4175 Royal Drive, Building 300<br>Kennesaw, GA 30144<br>(800) 272-4482<br>dlandis@petersenmail.com        |

Quality Assurance Representative  
Address/Phone/Email  
Tom Creigh, VP  
Petersen Aluminum, Inc.  
1005 Tonne Road  
Elk Grove, IL 60007  
(800) 722-7150  
tcreigh@petersenmail.com

Category  
Subcategory  
Panel Walls  
Soffits

Compliance Method  
Evaluation Report from a  
Florida Registered Architect  
or a Licensed Florida  
Professional Engineer  
 Evaluation Report -  
Hardcopy Received

Florida Engineer or Architect Name who  
developed the Evaluation Report  
Terrence E. Wolfe  
Florida License  
PE-44923  
Quality Assurance Entity  
UL LLC  
Quality Assurance Contract Expiration Date  
05/17/2015  
Validated By  
C. Keith Brasher  
 Validation Checklist -  
Hardcopy Received

Certificate of Independence  
[FL4483 R5 COI Letter of  
Certification.pdf](#)

Referenced Standard and Year (of Standard) **Standard** **Year**  
ASTM E330 2002

Equivalence of Product Standards  
Certified By

Sections from the Code

|                           |                   |
|---------------------------|-------------------|
| Product Approval Method   | Method 1 Option D |
| Date Submitted            | 06/14/2012        |
| Date Validated            | 06/25/2012        |
| Date Pending FBC Approval | 07/02/2012        |
| Date Approved             | 08/07/2012        |

### Summary of Products

| FL #  | Model, Number or Name      | Description   |
|---|----------------------------|---|
| 4483.1  | PAC 850<br>Aluminum Soffit | PAC 850 Aluminum Soffit x 12" wide, .032" Aluminum Soffit, Solid, Fully-Vented or 1/2 Vented.   |
| <b>Limits of Use</b><br><b>Approved for use in HVHZ:</b> No<br><b>Approved for use outside HVHZ:</b> Yes<br><b>Impact Resistant:</b> N/A<br><b>Design Pressure:</b> +N/A/- 110.9PSF<br><b>Other:</b> -24.27 psf @ 4'-0" o.c. - 110.93 psf @ 1'-0" o.c. Install per manufacturer's details. Not for use in HVHZ Zones. |                            | <b>Installation Instructions</b><br><a href="#">FL4483_R5_II_PAC_850_Details.pdf</a><br>Verified By: Terrence E. Wolfe, P.E. 44923<br>Created by Independent Third Party: Yes<br><b>Evaluation Reports</b><br><a href="#">FL4483_R5_AE_Letter_of_Compliance_to_the_2010_Code.pdf</a><br><a href="#">FL4483_R5_AE_PAC_850_Eval_rpt.pdf</a><br><a href="#">FL4483_R5_AE_PAC_850_Load_Table.pdf</a><br>Created by Independent Third Party: Yes |