



KEYNOTES:

- TRIM AND SUPPORT PLATE FASTENERS ARE SELF-DRILL PANCAKE HEAD AND MUST BE INSTALLED IN A STAGGERED PATTERN.
 - CLIPS, FASTENERS, AND SUPPORT PLATE MATERIAL: GALVANIZED WHEN STEEL PANELS ARE UTILIZED; STAINLESS STEEL WHEN ALUMINUM PANELS ARE UTILIZED.
 - SUPPORT PLATE AND CLIP FASTENERS MUST BE OF SUFFICIENT LENGTH TO PENETRATE LOWEST FLUTE OF METAL DECK BY 5/8" MINIMUM THREAD LENGTH.
- ① EAVE FLASHING HEM EDGE: 1 1/2" MINIMUM.
 - ② PANEL HEM AND THERMAL GAP CLEARANCE: MINIMUM 1 1/2" HEM WITH 1/2" CLEARANCE. (CONSULT FACTORY).
 - ③ FIRST PANEL CLIP TO BE LOCATED A **MAXIMUM OF 8" FROM EAVE**.
 - ④ ROOF SIDE FLANGE SHOULD BE STRIPPED IN WITH APPROVED UNDERLAYMENT.
 - ⑤ CLEAT: 24 GA. MINIMUM.
 - ⑥ SUPPORT PLATE: 20 GA. MINIMUM (IF WOOD NAILERS ARE PRESENT, SUPPORT PLATE IS NOT NEEDED)

Job Name _____ Contractor _____

Date _____ Notes _____