



1 Metal Roof Deck Panels* "Snap-Clad"	No. 24 MSG min. thickness coated steel. Panels 18 in. wide max., 10 in. wide min. 1-3/4 in. high at the ribs. Panels continuous over two or more spans. A bead of sealant may be used at panel side joints.
2 Roof Deck Fasteners* (Panel Clips) "Snap-Clad Clip"	One piece assembly, 3-1/2 in. wide, 1-7/8 in. high. One panel clip located at each purlin intersection.
3 Panel Fasteners (Screws)	Fasteners used to attach panel clips (item 2) to purlins to be No. 10-16 by 1 in. long cadmium plated pancake head No. 2 phillips drive, No. 3 self-drilling point steel screws. Two screws per clip to be used inserted through 1/4 in. diameter guide holes.
4 Purlins	No. 16 MSG min. thickness steel (50,000 psi min. yield strength). Spacing for Class 90 to be 48 in. OC: For Class 60 to be 60 in. OC

*Bearing the UL Classification Marking