


UL CONSTRUCTION NO. 617

UPLIFT - CLASS 90/ FIRE NOT INVESTIGATED



1 Metal Roof Deck Panels * / "Tite-Loc"

Minimum 24 MSG thick steel, 18 in. max, 12 in. min. width, 2 in. high at the ribs. A line of sealant may be used at panel ends and sidelaps. Sidelap to be tightened and crimped with an electric seaming machine to an angle of 90 degrees. Crimping process to include the upper portion of the panel clip (Item 2).

2 Roof Deck Fasteners* (Panel Clips)

Any of the following. Clip spacing to be 48 in. OC max. Sealant may be used at the top of the clips:

Tite-Loc Utility Clip: One piece assembly; 3 in. wide, approximately 2 in. high with two guide holes in base. Fabricated from No. 22 MSG coated steel.

Tite-Loc Low Fixed Clip: One piece assembly; 3 in. wide, approximately 2-3/8 in. or 3 in. high, with three guide holes in base. Fabricated from No. 22 MSG coated steel.

Tite-Loc Low Floating Clip: Two piece assembly; base approximately 2 in. wide, 1-11/16 in. long formed to engage upper tab. Fabricated from No. 16 MSG coated steel. Tab approximately 4-5/16 in. wide; 2-3/8 in. or 2-7/8 in. high, formed to engage base. Fabricated from No. 22 MSG coated steel. Base to have two guide holes.

Tite-Loc AR Floating Clip: Two piece assembly; base approximately 2 1/2 in. wide, 1-7/8 in. long formed to engage upper tab. Fabricated from No. 18 MSG coated steel. Tab approximately 4-5/16 in. wide; 2-3/8 in. high, formed to engage base. Fabricated from No. 22 MSG coated steel. Base to have two guide holes.

3 Fasteners (Screws)

The plywood deck is secured to the supports with 2-1/2 in. drywall screws spaced 6 in. on center at the perimeter and 12 in. on center in the field. The Tite-Loc clip is fastened to the deck with two #14-1/4 x1 in. long Phillips drive screws. Panel edges are attached to the plywood with 2-1/2 in. long drywall Phillip head screws, spaced 6 in. on center and 1 in. from the panel edge.

4 Supports

Wood No. 2 or better, 2 in. x 10 in. x 179 in., spaced 24 in. on center.

5 Plywood Decking

19/32 in. B-C grade APA Rated. All joints are sealed with a 1 in. wide urethane Caulk (Bostik Chem) cured for 16 hours. The entire deck is covered with an asphalt-saturated felt per the manufacturers installation instructions.

5A Oriented Strand Board (OSB) / (Not Shown)

As an alternate, nom. 5/8 in. thick (19/32 in. actual) APA rated OSB may be substituted for plywood decking (Item 5). Installation procedures are to be same as for plywood except that the clips shall be spaced a maximum of 30in.

Refer to General Information, Roof Deck Construction for items not evaluated.

*Bearing the UL Classification Marking

PETERSEN ALUMINUM CORPORATION

HQ: 1005 Tonne Road Elk Grove Village, IL 60007 P: 800-PAC-CLAD F: 800-722-7150 9060 Junction Drive Annapolis Junction, MD 20701 P: 800-344-1400 F: 301-953-7627 10551 PAC Road Tyler, TX 75707 P: 800-441-8661 F: 903-581-8592 102 Northpoint Parkway Acworth, GA 30102 P: 800-272-4482 F: 770-420-2533 1800 S. 7th Ave., Suite 130 Phoenix, AZ 85007 P: 833-750-1935 F: 602-254-6504

PAC-CLAD.COM SALES@PETERSENMAIL.COM

1885 Station Parkway NW, Suite B Andover, MN 55304 P: 877-571-2025 F: 866-901-2935