

NFPA 285

Architectural Technical Bulletin



PRODUCT

- ▶ **IWP Series:** Insulated Metal Wall Panel
- ▶ **Component:** Polyisocyanurate (PIR) insulating foam core
- ▶ **System:** Rubitherm WR 40618 / Rubinate 1850
- ▶ **Blowing Agent:** Non-ozone depleting Pentane

TEST PROTOCOL

- ▶ NFPA 285-12, Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components

TEST LOCATION:

- ▶ INTERTEK, 16015 Shady Falls Road, Elmendorf, TX 78112

REPORT NUMBER:

- ▶ 103176855SAT-003

RESULTS:

- ▶ The assembly described and tested herein **did** meet the Conditions of Acceptance for NFPA 285. Thus satisfying Chapter 26, Section 2603.5.5 of the International Building Code, 2015.

SUBJECT TO CHANGE WITHOUT NOTICE – Please visit our website for the most current information.

ATB-0007-R1

PAC-CLAD® is a registered trademark of Petersen Aluminum Corporation. 11/24



PAC-CLAD.COM | 800 PAC CLAD