



18" TITE-LOC PLUS, .040 ALUMINUM

Span	AISI Design Load, 2.0 Safety Factor	USOE Design Load: 1.65 Safety Factor
1.00	-203.00	-245.00
2.00	-140.00	-201.00
2.50	-112.00	-179.00
3.00	-93.00	-157.00
3.50	-80.00	-134.00
4.00	-70.00	-112.00
4.50	-62.00	-90.00
5.00	-56.00	-60.00

NOTES

1. Testing conducted per ASTM E-1592 Air Bag testing, negative uplifts.
2. Actual testing conducted at 1' 0 and 5' 0" spacing. Intermediate values have been interpolated.
3. All tests were performed by Fenestration Testing Laboratory.

5/21/2013

Petersen Aluminum Corporation
1005 Tonne Road
Elk Grove Village, IL 60007
tel: 800 323 1960
fax: 800 722 7150

visit our website @ www.pac-clad.com